

Table 4.19d. Permitted and Design Flows for Publicly Owned Wastewater Treatment Facilities in the Minnesota Lake Superior Basin

Facility	MPCA NPDES	USEPA Clean Water Needs Survey	
	Permitted Flow, Mgal/day	1996 Design Flow, Mgal/day	Future Design Flow, Mgal/day
Grand Marais	0.990	0.299	0.309
Beaver Bay	0.040	0.049	0.049
Silver Bay	0.830	0.829	0.849
Two Harbors	1.600	1.199	1.199
Aurora	0.910	0.309	0.319
Babbitt	land disposal	0.500	0.509
Biwabik	0.212	0.169	0.250
Buhl-Kinney	0.193	0.159	0.159
Chisholm	0.720	0.719	0.729
Eveleth	0.800	0.799	0.809
Floodwood	0.106	0.109	0.109
Gilbert	0.500	0.500	0.509
Hibbing-North	3.200	3.199	3.250
Hibbing-South	2.000	1.199	3.000
Hoyt Lakes	0.500	0.549	0.559
Iron Junction	0.010	0.009	0.009
McKinley	0.040	0.039	0.049
Meadowlands	0.025	0.029	0.029
Mountain Iron	0.550	0.549	0.559
Virginia	4.300	2.000	2.039
Western Lake Superior Sanitary District	43.630	43.629	55.000
Lake Superior Basin Total	61.156	56.842	70.293